



NOTES:

10'-0" OF FRONT OF TRANSFORMER AND
5'-0" OF ALL SIDES.

FROM:

- SIDEWALK 4'-0"
- WATER METER 4'-0"
- FIRE HYDRANT 10'-0"
- SEWER MANHOLE 10'-0"
- HOUSE WALL 15'-0"

* DEVIATIONS APPROVED ON A CASE BY CASE BASIS

2 CONDUITS (1 PER LOT) SHALL BE STUBBED UP
BEHIND EACH BOX PAD AND SECONDARY PEDESTAL



UNDERGROUND ROW GUIDE DRAWING

REVISED

DRAWN BY:
CJH

APPROVED BY:
JWM

DATE:
6-7-06

SCALE:
NTS